



NOTES

- (1) ALL FITTINGS SHALL BE MECHANICAL JOINT DUCTILE IRON BENDS.
- (2) ALL FITTINGS SHALL BE RESTRAINED WITH MEGA LUG THRUST RESTRAINTS.
- (3) NEW 10" PIPE SHALL BE CLASS 350 DUCTILE IRON.
- (4) ALL WORK & MATERIALS SHALL MEET CITY OF CAYCE SPECIFICATIONS.
- (5) CITY ENGINEER SHALL BE NOTIFIED PRIOR TO STARTING THIS CONSTRUCTION.

**WATERLINE RELOCATION SCHEMATIC**

NTS